Approved For Release 2001/08/31 : CIA-RDP78-04915A000400010090-0

COST ESTIMATE

25X1A [redacted] - ELECTRICAL SERVICE

The cost of providing power service, utilising Route C, is broken down as follows:

Pole line - 425 feet	$ 950.00
Transformer Sub-Station	6,000.00
Powerhouse, including ventilating	3,000.00
Powerhouse electrical work, including installation of generators.	2,000.00
Fuel System	600.00
Low Voltage Feeder	1,500.00
25X1A * Increase size of [redacted] feeder	500.00
	$ 15,450.00
Contingency Fund - 10%	1,545.00
	$ 16,995.00

* See sub-paragraph k. under "FACTS BEARING ON THE PROBLEM". This feeder runs warm with present operation. Addition of one conductor will permit three-phase loading and increase the feeder carrying capacity by at least 50%.

Approved For Release 2001/08/31 : CIA-RDP78-04915A000400010090-0